



NOTES

- ① ROMAC PART# 511-3.50 X 3.50 X 7SSFE WITH NBR GASKETS
- ② 3"Ø X 32" PIPE (ONE END THREADED)
- ③ 3"X 3"X 3" THREADED TEE (150psi)
- ④ 3"Ø X 7-1/4" PIPE (BOTH ENDS THREADED)
- ⑤ 3" S.S. STREAM FLOW BALL VALVE MODEL BV150SS3FP S.S. FULL PORT S.S. BALL VALVE THREADED HANDLE CUT TO FIT MAXIMUM CLEARANCE 1" REMOVE LATCH LOCK
- ⑥ 3"Ø X 4" NIPPLE (BOTH ENDS THREADED)
- ⑦ 3" CAM & GROOVE MALE ADAPTOR BY 3" MALE N.P.T. (BRASS)
- ⑧ 3" CAM & GROOVE DUST CAP (BRASS)

NOTES:
 BALL VALVES AND TEE ASSEMBLIES ARE VERTICAL TO LPFM BUT ARE SHOWN HORIZONTAL FOR CLARITY
 SEE COUPLING DETAIL FOR ALL ROMAC COUPLING POSITIONS
 FOR A SMALLER SIDELINE SEE LPPM28 & LPPM29 DRAWINGS.

GENERAL NOTES:

* ALL MATERIALS MUST BE 304 STAINLESS STEEL SCHEDULE 40 (EXCEPT AS NOTED)

EXPLODED TOP VIEW
 NOT TO SCALE

THE
 METROPOLITAN SEWER DISTRICT
 OF
 GREATER CINCINNATI

**3" LOW PRESSURE FORCE MAIN
 LEFT TEE FLUSHING CHAMBER DETAIL**